

April 22, 2016

TO: All Bidders

RE: Informal Bid 2016-08 Addendum # 2

### **ADDENDUM NO. 2**

This **ADDENDUM #2** forms part of Moore County's Informal Bid for Liquid Polymer for the County of Moore Water Pollution Control Plant. All requirements of the original specifications remain in effect in their respective order. **Receipt of this Addendum must be acknowledged by its inclusion with the Informal Bid and noted as an inclusion on the sealed envelope.**

**Note: MANDATORY Project Test must be completed by Friday April 29, 2016. Sealed Bids are due by 4:00 pm Thursday, May 26, 2016.**

1. Question: Can the testing date be extended, if not can a previous test be considered?  
Answer: The testing date cannot be extended and previous tests will not be considered.
2. Question: Do we have to be present for the bid opening?  
Answer: The bid opening is not public.
3. Question: Do we have to be present to run the trail pails?  
Answer: No
4. Question: What is the feed solid %?  
Answer: Waste sludge 1%; digested 3-5%

Questions will be accepted until 10:00 am Thursday, May 5, 2016. Proposals are due to Terra Vuncannon at 206 South Ray Street Carthage NC 28327 by 4:00 pm May 26, 2016.

**END OF ADDENDUM NO. 2**

Terra Vuncannon  
Purchasing Manager  
County of Moore